



**The Corporation of the Town of Essex**

**Addendum 1**

**Request for Tender RFT-ID-23-020**

**Concrete Sidewalk Construction - 2023**

**Closing Information:**

**Date:** June 07, 2023  
**Time:** 11:00.00 AM Local Time  
**Location:** Town of Essex Municipal Offices  
33 Talbot Street South  
Essex, Ontario N8M 1A8

TO DOWNLOAD AN UNMARKED VERSION OF THIS FILE  
WWW.BIDSANDTENDERS.COM - ORIGINAL DOCUMENT SOURCE

**PREVIEW**

## Announcement

The closing time of this Request for Tender has been changed to:-

June 07, 2023, at 11:00:00 AM Local Time

## Question and Answer

Q.1 For the Section c Rehabilitation of the Church street - Centre street to Munger street (Harrow) The side where it is to be removed only does it need to be restored? If so with what specifications. this would be the area marked in green. Also the Section D Tully Meadows Trail entrance is the quantity to be in tonnes? as I am not sure how to price the fabric and the excavation by the tonne.

A.1 Section C – Rehabilitation – Church Street – Centre Street to Munger Street (Harrow)

All damaged areas are to be restored with high quality topsoil (compacted then top dressed) free of weeds and seeded with high quality grass seed raked in. Seed/grass is to be continuously watered by the contractor to ensure growth until the grass has taken is able to be cut.

Section D – Tulley Meadows Trail Entrance – Woodview Drive (Essex)

Tonnes is the quantity of granular A that is to be compacted based on a 3m wide 150mm thick multi-use path. Excavation and geo fabric is to be included in the pricing of the granular A. The approximate granular area is 115 square metres.

**END**